

CERTIFICATE EU-TYPE EXAMINATION Module B

No. 191299167

issued in accordance with Annex No. III, Part 1, to Regulation (EU) 2016/426 of the European Parliament and of the Council

Manufacturer: **Kleine Kessel S.r.l.**
Via Solferino 55/E, 25122 Brescia (BS)
Italy

Product: **Wall Hung Condensing Range Rated Boilers burning gaseous fuels**
type „C₁₃“; „C₃₃“; „C₄₃“; „C₅₃“, category II_{2H3P}
GRUPPO IMAR THEA ER 35, THEA EN 35

Models: **THEA EN 35: 35 kW outdoor condensing gas boilers for CH only**
THEA ER 35: 35 kW outdoor condensing gas boilers for CH and DHW

Product ID Number: **CE-1299CU0167**

This certificate TSÚ Piešťany, š.p. as Notified Body confirms the conformity the tested sample with the essential safety requirements of the following European Legislation:

**REGULATION (EU) 2016/426 OF THE EUROPEAN PARLIAMENT AND OF THE COUNCIL
on appliances burning gaseous fuels**

Certificate has been issued on the basis of this document: Conformity assessment report
No. 190500136 Dated of 4 June 2019.

Issue date: 4 July 2019
Expiry date: 3 July 2029 (Following procedure according to Module C2)
Issue: 1



[Signature]
Ing. Dušan Hanko
on behalf of TSU Piešťany, š.p., NB 1299

114735

Specification

Countries of destination	Supply pressures	Appliances categories
AT Austria	20 mbar	I _{2H}
BE Belgium	37 mbar	I _{3P}
BG Bulgaria	20 mbar, 37 mbar	II _{2H3P}
CH Switzerland	20 mbar, 37 mbar	II _{2H3P}
HR Croatia	20 mbar, 37 mbar	II _{2H3P}
CZ Czech Republic	20 mbar, 37 mbar	II _{2H3P}
DK Denmark	20 mbar	I _{2H}
EE Estonia	20 mbar, 37 mbar	II _{2H3P}
ES Spain	20 mbar, 37 mbar	II _{2H3P}
FI Finland	20 mbar	I _{2H}
GB Great Britain	20 mbar, 37 mbar	II _{2H3P}
GR Greece	20 mbar, 37 mbar	II _{2H3P}
HU Hungary	25 mbar, 37 mbar	II _{2H3P}
IE Ireland	20 mbar, 37 mbar	II _{2H3P}
IT Italy	20 mbar	I _{2H}
LT Lithuania	20 mbar	I _{2H}
LV Latvia	20 mbar, 37 mbar	II _{2H3P}
PL Poland	37 mbar	I _{3P}
PT Portugal	20 mbar, 37 mbar	II _{2H3P}
RO Romania	20 mbar, 37 mbar	II _{2H3P}
SK Slovakia	20 mbar, 37 mbar	II _{2H3P}
SI Slovenia	20 mbar, 37 mbar	II _{2H3P}
SE Sweden	20 mbar	I _{2H}
TR Turkey	20 mbar, 37 mbar	II _{2H3P}

European harmonized standards used for the conformity assessment:

EN 15502-1: 2012; A1: 2015

EN 15502-2-1: 2012; A1: 2016

EN 15502-2-2: 2014

The rules for use of this certificate.

It is forbidden to modify, amend or rewrite the data in the certificate.

This certificate cannot be used as a certificate for product, where a change influencing conformity with the applied normative documents and regulations was done without approval of the TSÚ Piešťany, š.p.

Manufacturer have to choose together with the module B either module C2 or module D. In the separate module B is impossible to affix the CE marking with Notified Body Number for the product /s.

